



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listed model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	Ningbo Ginlong Technologies Co., Ltd.	<b>Manufacturer:</b>	Ningbo Ginlong Technologies Co., Ltd.
<b>Address:</b>	No. 57 Jintong Road, Seafront (Binhai) Industrial Park, Xiangshan Economic Development Zone, Xiangshan, Ningbo, Zhejiang	<b>Address:</b>	No. 57 Jintong Road, Seafront (Binhai) Industrial Park, Xiangshan Economic Development Zone, Xiangshan, Ningbo, Zhejiang
<b>Country:</b>	CHINA	<b>Country:</b>	CHINA
<b>Contact:</b>	Mr. Wang Yiming	<b>Contact:</b>	Mr. Wang Yiming
<b>Phone:</b>	0086-574-65781806	<b>Phone:</b>	0086-574-65781806
<b>FAX:</b>	0086-574-65781606	<b>FAX:</b>	0086-574-65781606
<b>Email:</b>	info@ginlong.com	<b>Email:</b>	info@ginlong.com
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Intertek Testing Service Shanghai		

**Control Number:** 3186984

**Authorized by:**

Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	UL Standard for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, UL 1741, Second Edition, January 28, 2010 & General Use Power Supplies, CSA C22.2 No.107.1-01 dated September, 2001, Reaffirmed 2011 with Interim Certification Requirements for Utility-Interconnected Inverters - CSA Technical Information Letter (T.I.L.) No. I-43, dated January 21, 2011
<b>Product:</b>	Grid-Tie Inverter
<b>Brand Name:</b>	Ginlong, Solis
<b>Models:</b>	GCI-*K-2G-*, Solis-*K-2G-*
	The first "*" could be numbers, The second "*" could be letters with or without punctuation characters.

## AUTHORIZATION TO MARK

Product	Grid-Tie Inverter
Brand name	Ginlong, Solis
Description	The products covered by this report are single-phase, non-isolated, grid connected inverters for alternative energy generation with a rating from 1kW to 5kW.
Models	GCI-*K-2G-*, Solis-*K-2G-*
	The first "*" could be numbers, The second "*" could be letters with or without punctuation characters.
Model Similarity	<p>Explanation of model series GCI-*K-2G-*</p> <p>The first "*" stands for nominal AC power rating of the inverter from 1kW to 5kW, respectively are 1, 1.5, 2, 2.5, 3, 3.6, 4, 4.6 or 5.</p> <p>The second "*" stands for input source type of the inverter, which could be US, W-US or H-US. US stands for Photovoltaic modules, W-US stands for Wind turbine, H-US stands for Hybrid input source.</p> <p>Explanation of model series Solis-*K-2G-*</p> <p>The first "*" stands for nominal AC power rating of the inverter from 1kW to 5kW, respectively are 1, 1.5, 2, 2.5, 3, 3.6, 4, 4.6 or 5.</p> <p>The second "*" stands for input source type of the inverter, it could only be US, which stands for Photovoltaic modules.</p> <p>The models with the same nominal AC power rating have identical hardware, software and structure except the name on marking.</p> <p>The models with different nominal AC power rating have similar circuit diagram, constructions and enclosure except with different sizes of heatsink, power devices and ratings.</p>
Ratings	Refer to section 7 Illustration 2 - Ratings
Other Ratings	NA